




Product Service

# CERTIFICATE

No. Z2 116651 0003 Rev. 00

**Holder of Certificate:** **EPP Energy Peak Power GmbH**  
Danckwerthweg 25  
22119 Hamburg  
GERMANY

**Certification Mark:**



**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 701262208503-00

**Valid until:** 2026-11-28

**Date,** 2022-05-12

( Zhulin Zhang )

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



# CERTIFICATE

No. Z2 116651 0003 Rev. 00

**Model(s):** EPPxxx-144MG, xxx=380 to 415, in step of 5  
 EPPxxx-120MG, xxx=315 to 345, in step of 5  
 EPPxxx-144M, xxx=410 to 460, in step of 5  
 EPPxxx-120M, xxx=340 to 385, in step of 5  
 EPPxxx-144M10, xxx=520 to 550, in step of 5  
 EPPxxx-132M10, xxx=480 to 505, in step of 5  
 EPPxxx-120M10, xxx=435 to 460, in step of 5  
 EPPxxx-108M10, xxx=390 to 415, in step of 5  
 EPPxxx-120M12, xxx=580 to 605, in step of 5  
 EPPxxx-110M12, xxx=530 to 555, in step of 5,  
 xxx is standing for rated output power at STC

**Parameters:**

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790.

**Tested according to:**

- IEC 61215-1:2016
- IEC 61215-1-1:2016
- IEC 61215-2:2016
- IEC 61730-1:2016
- IEC 61730-2:2016
- IEC 62716:2013